

Tender Addendum



Tender No: RFT 06/2024
Project: 2024/25 Reseal Program
Date: 30th August 2024
Subject: Addendum No. 2

This addendum is to share Council's response to a below query from a prospective tenderer.

Question:

- The addendum states supply and place 100mm thick 20si I have no issue there but maybe some clarification on unit? Are we to price this as 1m² rate not having any idea of actual quantity or maybe a above and below rate say 100m² and below, 100m² and above as these rates change considerably? My suggestion it would be a per tonne rate. Also, this is obviously exclusive of excavation/milling? I feel some clarification here would save hassles latter on if you are to use this treatment.

Responses:

- Supply, place, and compact 100mm thick AC20SI structural asphalt. The estimated quantity ranges from 300 to 700 tons. The contractor must provide all asphalt quantity dockets if supplied unit rate is based on tonnage.
- The rate should include excavation/milling and disposal off site. The estimated area is above 2700m². Rate to supply in meter square.

[end of Tender Addendum No. 2]

We hereby acknowledge receipt of the above-referenced Addendum to the Request to Tender, and the Tender Addendum No. 1 shall be incorporated into our Tender submission.

Name of Company: _____

Signature of Authorised Representative: _____

Name/Title [print]: _____

A handwritten signature in black ink, appearing to read 'Naresh Bista', with a stylized flourish at the end.

Naresh Bista

COORDINATOR – ENGINEERING & PROJECTS